

**Mandatory Language for Monitoring and Reporting Violation
Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)**

CITY OF HASKELL PWS 1040001 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

Type of violation: DLQOR

This violation(s) occurred in the monitoring period(s) 2Q2020, 4Q2019, 3Q2014, 1Q2014, 4Q2013, 3Q2013

We are taking the following actions to address this issue: We submitted our DLQOR to TCEQ in a timely manner and returned all our same or similar violations to compliance as of 11/18/2020. <corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact

Water System Official: Jeff Sorrells Area code + Phone number: (940) 200-1719

Posted Date / Delivered on: April 29th 2025

Instructions for preparing the required Public Notice:

Reply to this email with copies of all completed, signed and data documents for our review.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) or Notice of Enforcement to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than 90 days after the violation was identified. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.



Texas Commission on Environmental Quality
Protecting Texas by Reducing and Preventing Pollution

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS
 Public Notice to be posted within 12 months of violation notification

Public Water System (PWS) name CITY OF HASKELL PWS 1040001

Type violation: DLQOR Time Period of violation: 2Q2020, 4Q2019, 3Q2014, 1Q2014, 4Q2013, 3Q2013

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122 and;

Make an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

COMMUNITY WATER SYSTEM:

☒ * Mail or directly distribute PN to each customer receiving a bill and to other service connections to which water is delivered by the public water system and at least one of the following methods if direct delivery may not reach all persons regularly served by the system:

☐ Publish PN in local newspaper

☐ Post PN by continuous posting in conspicuous places within the service area

☐ Deliver multiple PNs to single-bill addresses serving several persons (e.g., apartment building owners or large private employers)

☐ Deliver PN to community organizations

☒ * Post PN on the Internet at: www.haskelltexasusa.com

NONCOMMUNITY WATER SYSTEM:

☐ Post PN in conspicuous places within the water system, or

☐ Mail or directly deliver PN to each customer and service connection

and at least one of the following methods if direct delivery or public posting may not reach all persons regularly served by the system:

☐ Publish PN in local newspaper or newsletter

☐ Send e-mail to notify students or employees

☐ Deliver PN in public places (e.g., community centers)

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Winston Stephens

Title: City Manager

Phone: (940) 207-1855

Date of Delivery to Customers: 7/1/25

Signature: [Signature]

Date Signed: 7/1/25

Reply to this email with all completed, signed and dated copies for our review. Or you can

mail a copy of this completed form and a copy of the Public Notice that was delivered to your customers to:

TCEQ - Drinking Water Inventory & Protection Team
Attn: Public Notice (MC-155)
P. O. Box 13087
Austin, TX 78711-3087